

Drinking Water Quality and Compliance  
**Town Short Form – A Template for Annual Notice to Consumers**

(Note: This short form may be used for communities or waterworks serving a population of less than 5000).

**Introduction**

Saskatchewan Environment (SE) requires that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Minister's Order or Permit to Operate a waterworks. The following is a summary of the **Village of Theodore's** water quality and sample submission compliance record for the 2010 calendar year. This report was completed on June 21, 2011. Readers should refer to SE's "Municipal Drinking Water Quality Monitoring Guidelines, November 2002, EPB 202" for more information on minimum sample submission requirements and the meaning of type of sample. Permit requirements for a specific waterworks may require more sampling than outlined in the department's monitoring guidelines. If consumers need more information on the nature and significance of specific water tests, more detailed information is available from [www.saskh20.ca](http://www.saskh20.ca).

**Water Quality Standards**

**Bacteriological Quality**

Parameter/Location	Limit	Regular Samples Required	Regular Samples Submitted	# of Positive Regular Submitted (%)
Total Coliform and Background Bacteria	0 Organisms/100 mL Less than 200/100 mL	26	27	0%

**Water Disinfection –**

**Chlorine Residual in Distribution System for Test Results Submitted with Bacteriological Samples**

Parameter	Minimum Limit	Total Chlorine Residual Range	Free Chlorine Residual Range	# Tests Required	# Tests Submitted	# Adequate Chlorine (%)
Chlorine Residual	0.1 mg/L free OR 0.5 mg/L total	.15 – 1.6 mg/L	.10 – 1.05 mg/L	27	27	100%

**Water Disinfection - Free Chlorine Residual for Water Entering Distribution System from Waterworks**

**Records-From Water Treatment Plant Records**

Parameter	Limit (mg/L)	Test Level Range	# Tests Performed	# Tests Not Meeting Requirements
Free Chlorine Residual	at least 0.1	.07 – 1.05 mg/L	378	3

*A minimum of 0.1 milligrams per litre (mg/L) free chlorine residual is required for water entering the distribution system. Tests are normally performed on a daily basis by the waterworks operator and are to be recorded in operation records. This data includes the number of free chlorine residual tests performed, the overall range of free chlorine residual (highest and lowest recorded values) and the number of tests and percentage of results not meeting the minimum requirement of 0.1 mg/L free chlorine residual.*

**Turbidity – From Water Treatment Plant Records**

Parameter	Limit (NTU)	Test Level Range	# Tests Not Meeting Requirements	Maximum Turbidity (NTU)	# Tests Required	# Tests Performed
Turbidity	1.0	.23 - 1.76	56	1.76	365	370

**Chemical – Health Category**

All waterworks serving less than 5000 persons are required to submit water samples for SE's Chemical Health category once every 2 years. The Chemical Health category includes analysis for arsenic, barium, boron, cadmium, chromium, fluoride, lead, nitrate, selenium and uranium.

The last sample for Chemical Health analysis was required in 2010 and submitted on August 24, 2010.

Parameter	Limit MAC (mg/L)	Limit IMAC (mg/L)	Sample Result(s)	# Samples Exceeding Limit
Aluminum	none set		0.0005	0
Arsenic	0.025		0.7	1
Barium	1.0		0.0082	0

Boron		5.0	0.38	0
Cadmium	0.005		0.00001	0
Chromium	0.05		<0.0005	0
Copper	1.0		0.018	0
Fluoride (avg*)	1.5		0.21	0
Lead	0.01		0.0002	0
Nitrate (avg.*)	45.0		16	0
Selenium	0.01		0.0001	0
Uranium	0.02		7.2	1
Zinc	5.0		0.013	0

\*Results expressed as average values for communities or waterworks that fluoridate drinking water supplies or those with elevated concentrations of fluoride or nitrates.

### **General Chemical**

<b>Parameter</b>	<b>Aesthetic Objectives * (mg/L)</b>	<b>Sample Results (average)</b>	<b># Samples Required</b>	<b># Samples Submitted</b>
Alkalinity	500	458	1	1
Bicarbonate	No Objective	559	1	1
Calcium	No Objective	137	1	1
Carbonate	No Objective	<1	1	1
Chloride	250	72	1	1
Conductivity	No Objective	2420	1	1
Hardness	800	679	1	1
Magnesium	200	82	1	1
PH	No Objective	7.86	1	1
Sodium	300	329	1	1
Sulphate	500	810	1	1
Total dissolved Solids	1500	1740	1	1

All waterworks serving less than 5000 persons are required to submit water samples for SE's General Chemical category once every two years if a ground water source and once per three months every second year if a surface water or blended surface/groundwater source. The General Chemical category includes analysis for alkalinity, bicarbonate, calcium, carbonate, chloride, conductivity, hardness (as CaCO<sub>3</sub>), magnesium, sodium, sulphate and total dissolved solids.

\*Objectives apply to certain characteristics of or substances found in water for human consumptive or hygienic use. The presence of these substances will affect the acceptance of water by consumers and/or interfere with the practice of supplying good quality water. Compliance with drinking water aesthetic objectives is not mandatory as these objectives are in the range where they do not constitute a health hazards. The aesthetic objectives for several parameters (including hardness as CaCO<sub>3</sub>, magnesium, sodium and total dissolved solids) consider regional differences in drinking water sources and quality.

### **More information on water quality and sample submission performance may be obtained from:**

Village of Theodore  
 Box 417  
 Theodore, SK  
 S0A 4C0